

Triple IR Conventional Flame Detector



Product overview

Product	Triple IR Conventional Flame Detector
Part No.	55000-019

Product information

The Triple IR Conventional Flame Detector is designed to protect areas where open flaming fires may be expected.

Features

The Triple IR Conventional Flame Detector is sensitive to low-frequency, flickering infra-red (IR) radiation emitted by flames during combustion. Since it responds to flickering radiation the Triple IR Conventional Flame Detector can operate even if the lens is contaminated by a layer of oil, dust, water-vapour or ice.

The Triple IR Conventional Flame Detector is set to respond to low-frequency radiation at 1 to 15 Hz (1 to 2.7 μm) in order to detect all flickering flames including those invisible to the naked eye, e.g. those emitted by hydrogen fires.

The Triple IR Conventional Flame Detector has three IR sensors that respond to different IR wavelengths in order to discriminate between flames and spurious sources of radiation. False alarms due to such factors as flickering lighting are avoided by a combination of filters and signal processing techniques.

Electrical considerations

The Triple IR Conventional Flame Detector signals an alarm state by switching an alarm latch on, increasing the current drawn from the supply from 8 mA to 28 mA and closing the contacts of a fire relay RL1. These signals from the detector are recognised by the control panel as an alarm signal.

The alarm current also illuminates the detector integral red LED. A fault relay RL2 closes its volt-free contacts if the detector has no faults and the supply voltage to the detector is the correct value.

To ensure correct operation of the detector the control panel must

Technical Data

All data is supplied subject to change without notice. Specifications are typical at 24V, 23°C and 50% RH unless otherwise stated.

Supply voltage	14 - 30 V dc
Quiescent current	
RL2 energised	8 mA
Current loop, RL2 off	4 mA
RL2 off	3 mA
Alarm current	
RL1 and RL2 energised	28 mA
Current loop, RL1 and 2 off	20 mA
RL1 energised	9 mA
Remote detector test input	14 - 30 V dc
Alarm indicator	Red LED
Minimum holding voltage	2 V
Minimum voltage to illuminate indicators	12 V
Alarm reset voltage	6 V
Alarm reset time	1 second
Power-up time	2 seconds
Range of view	0.1 m ² n-heptane at 25 m
Sensitivity	Class 1 (EN 54-10)
Field of view	90° cone
Spectral response	IR ³ 0.75 to 2.7 μm
Operating temperature	-10°C to 55°C
Humidity (no condensing or icing)	0% to 95% RH
Standards and approvals	LCPB Cert: 729a/01, CPD Cert: 0832-CPD-0595
IP rating	IP65
Dimensions	108 mm wide x 142 mm high x 82 mm depth
Weight	2 kg
Materials	Die-cast zinc alloy

be arranged to supply a maximum of 30 Volts dc and a minimum of 14 Volts dc in normal operation.

To restore the detector to quiescent condition after indicating a fire it is necessary to extinguish any flames in view and interrupt the electrical supply to the detector for a minimum of one second.

Removing the detector front cover provides access to the detector terminals and configuration DIL switch.

The detector is normally configured to latch into an alarm state when a flame is in view. The configuration DIL switch within the detector can be set to place the detector into a non-latching mode. The detector can then also produce proportional analogue current alarm signals, i.e. 8 - 28 mA or 4 - 20 mA. In non-latching mode the detector only produces an alarm signal when a flame is in view, resetting itself to normal a few seconds after the flame has gone.

Note: When using this detector please avoid direct or reflected sunlight on the optics, prolonged ambient temperatures above 55°C and obstructions to the field of view.

36 Brookside Road, Havant | Tel: +44 (0)23 9249 2412 | Email: sales@apollo-fire.com
Hampshire, PO9 1JR, UK. | Fax: +44 (0)23 9249 2754 | Web: www.apollo-fire.co.uk



A HALMA COMPANY

© Apollo Fire Detectors Limited 2017

